Certified Validation Report: Provided by Validator

Audit Information:

Water Supplier Name: **San Jacinto**   PWS ID: **3310032**

System Type: **Potable**   Audit Period: **Calendar 2017**

Utility Representation: **Rita Ramirez, Crystal Yanez, Art Mullen**

Validation Date: **September 19th, 2019**   Meeting Time: **9:15 AM**   Sufficient Supporting Documents Provided: **Yes**

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: **67** Data Validity Band (Level): **Band III (51-70)**

ILI: **3.13**   Real Loss: **63.64 gallons/connection/day**   Apparent Loss: **2.69 gallons/connection/day**

Non-revenue water as percent of cost of operating system: **4.6%**

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ⊠

If not, rejected recommendations are included here.

Validator Information:

Water Audit Validator : **Aretha Samuel, Tanmay Thakur**   Qualifications: **Water Audit Validator Certificate issued by the CA-NV Section of the AWWA**